

#### **Features**

- Five signal to output ratios meet most control element requirements.
- Control sensitivity of 1" water column allows use in precision applications.
- Large Supply and Exhaust Valves provide high forward and exhaust flows.
- Soft Supply and Exhaust Valve seats minimize air consumption.
- A balanced Supply Valve minimizes the effect of supply pressure variation.
- An Aspirator Tube compensates downstream


pressure droop under flow conditions.


- A separate Control Chamber isolates the diaphragm from the main flow to eliminate hunting and buzzing.
- Optional remote feedback port minimizes pressure drop at final control element under flow conditions.
- The optional adjustable By-pass Valve lets you tune for optimum dynamic response. (1:1 ratio only)
- Unit construction lets you service the Model 4500A without removing it from the line.
- Canadian Registration Number (CRN) certification for all territories and provinces.


# **Operating Principles**

When signal pressure on the top of the Signal Diaphragm creates a downward force on the Diaphragm Assembly, the Supply Valve opens. Output pressure flows through the Outlet Port and the Aspirator Tube to the Control Chamber to create an upward force on the bottom of the Control Diaphragm. When the setpoint is reached, the force of the signal pressure that acts on the top of the Signal Diaphragm balances with the force of the output pressure that acts on the bottom of the Control Diaphragm to close the Supply Valve.

When the output pressure increases above the signal pressure, the Diaphragm Assembly moves upward to close the Supply Valve and open the Exhaust Valve. Because the Poppet Valve is closed, pressure flows down the Connecting Tube to the bottom of the Motor Diaphragm. This pressure keeps the Supply Valve tightly closed while in the exhaust mode. The Poppet Valve opens and excess output pressure exhausts through the vent in the side of the unit until it reaches the setpoint.










4500A



### **Technical Information**



## **Specifications**

	RATIO	1:1	1:2	1:3	2:1	3:1
Maximum Output Pressure	psig [BAR] (kPa)	150 [10.0] (1000)	150 [10.0] (1000)	150 [10.0] (1000)	75 5 [5.0] [ (500)	1 -
Maximum Supply Pressure	psig [BAR] (kPa)	250 [17.0] (1700)	250 [17.0] (1700)	250 [17.0] (1700)	250 2 [17.0] (1700)	
Flow Capacity 100 psig, [7.0 BAR] (700 kPa) supply, 20 psig, [1.5 BAR], (150 kPa) setpoint.	SCFM m³/HR	150 (255)	150 (255)	150 (255)	150 (255)	150 (255)
Downstream Pres 5 psig, [.35 BAR], (35 kPa) above 20 psig, [1.5 BAR], (150 kPa) setpoint.	ssure SCFM m³/HR	40 (65.2)	40 (65.2)	40 (65.2)	40 (65.2)	40 (65.2)
Setpoint Water Column	(cm)	1" (2.54)	2" (5.08)	3" (7.62)	2" (5.08)	2" (5.08)
Ratio Accuracy % of 100 psig, [7.0 BAR], (700 kPa) output span.		3.0	3.0	3.0		
% of output span w 100 psig, [7.0 BAR] (700 kPa) input spa	,				3.0	3.0
Supply Pressure Effect	psig [BAR] (kPa)	0.10 [.007] (0.7)	0.20 [.014] (1.4)	0.30 [.021] (2.1)	0.10 ( [.007] (0.7)	0.10 [.007] (0.7)

Ambient Temper
----------------

-40 °F to 200°F, (-40°C to 93.3°C)

### **Hazardous Locations**

Acceptable for use in Zones 1 and 2 for gas atmosphere; Groups IIA and IIB and Zones 21 and 22 for dust atmospheres

#### **Materials of Construction**

Body and Housing	Aluminum
Trim	Zinc Plated Steel, Brass
Diaphragm	Nitrile on Dacror

# **Catalog Information**

Catalog Number	4 5		A	
Ratio			T	
1:1		1		
1:2		2		
1:3		3		
2:1		4		
3:1		5		
Pipe Size				
3/8" NPT			3	
1/2" NPT			4	
3/4" NPT			6	
Options				Щ
Tapped Exhaust				Е
By-pass Valve <sup>1</sup>				1
Feedback				Р
BSPT (Tapered)				U
BSPP (Parallel) <sup>2</sup>				Н
Viton Flastomers 3				J

#### Installation

For installations instructions, refer to the corresponding *Fairchild Model 4500A Pneumatic Volume Booster Instruction, Operation and Maintenance Instructions, IS-2004500A.* 





<sup>&</sup>lt;sup>1</sup> For 1:1 Ratio Only

<sup>&</sup>lt;sup>2</sup> BSPP Threads in Inlet & Outlet. Others BSPT

<sup>&</sup>lt;sup>3</sup> Available on 1:1, 1:2 and 2:1 Only